



Town of Mansfield

6 Park Row, Mansfield, Massachusetts 02048

Department of Public Works

Town Engineer/ Assistant DPW Director

Richard C. Alves, Jr., PE

MEMORANDUM

TO: Sara Raposa, AICP, Director of Planning & Development

FROM: Richard C. Alves, Jr. PE, Town Engineer/Assistant DPW Director/*RCA*

DATE: May 22, 2023

SUBJECT: Site Plan Application, 89 Forbes Boulevard

The Engineering Division has reviewed the Site Plans prepared by Zenith Consulting Engineers, LLC. Revision dated 5/17/2023 and Phase II Stormwater Report & Study

The Engineering Division has reviewed the referenced documents and finds all previous comments and questions to be satisfied except the following.

1. There appears to be a discrepancy with elevations between the drainage calculations and what is show on the Grading and Drainage Plan Please verify
2. Please provide the elevations on the detail for the Infiltration Chamber Field along with the 100 year flood elevation.
3. Please note the slope granite curb detail is acceptable for the curb cut closer on Forbes Boulevard only. This matches the existing curbing.

Cc: Robert Blackman, Inspector of Buildings & Zoning Enforcement Officer
Katelyn Merrill, Environmental & Conservation Planner
Andrew Littig, Highway Operations Manager